

# The Do's and Don'ts of Safe LPG Tank Storage


## DO...



Consult Calor regarding the required distance from anything planned to surround the tank, such as buildings, structures, screenings, vegetation, sheds, fences, drains or openings.



Use Calor engineers to carry out any work on your tank and use an LPG-Qualified and Gas Safe Registered engineer for any associated infrastructure.



Keep all flammable material well away.



Ensure all areas of the tank are accessible for our Calor engineers and delivery drivers to maintain and refill the tank.



Seek advice from Calor's team of qualified engineers who can advise on the best positioning and maintenance for your LPG tank.

## DON'T...



Be tempted to move your tank even when not in use.




Move, disconnect or connect an LPG tank yourself - you need Calor's permission and expertise to do this.



Disregard the safety distances calculated when the tank was first installed.



Build any structures or park a vehicle over an underground tank. It's also important that you do not alter ground finish levels.



Build any other structure around or near the LPG tank or store it inside a building.



For all enquiries about your LPG tank storage, please contact our Customer Engineering Team 0345 6054500.  
For gas emergencies, please contact us on 0345 7444999.